



---

## FILL CERTIFICATE

PROJECT: Lot No 339 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_339

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 339, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 340 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_340

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 340, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 341 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_341

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 341, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 342 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_342

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 342, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 343 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_343

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 343, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 344 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_344

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 344, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 345 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_345

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 345, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 346 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_346

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 346, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry





---

## FILL CERTIFICATE

PROJECT: Lot No 347 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_347

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 347, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 348 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_348

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 348, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 349 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_349

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 349, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 350 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_350

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 350, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 351 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_351

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 351, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 352 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_352

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 352, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 353 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_353

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 353, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 354 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_354

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 354, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry





---

## FILL CERTIFICATE

PROJECT: Lot No 355 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_355

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 355, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 356 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_356

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 356, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 357 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_357

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 357, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 358 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_358

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 358, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 359 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_359

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 359, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 360 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_360

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 360, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 361 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_361

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 361, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 362 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_362

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 362, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry





---

## FILL CERTIFICATE

PROJECT: Lot No 363 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_363

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 363, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 364 (as per Drawing No 36182/3B R04)  
Trillium Estate (Stage 3B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14070\_364

DATE: 17/02/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of the Trillium Estate (Stage 3B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 364, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 13<sup>th</sup> December 2013.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry