



---

## FILL CERTIFICATE

PROJECT: Lot No 525 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_525

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 525 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 526 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_526

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 526 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 527 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_527

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 527 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 528 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_528

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 528 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 529 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_529

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 529 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 530 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_530

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 530 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 531 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_531

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 531 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 532 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_532

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 532 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



## FILL CERTIFICATE

PROJECT: Lot No 533 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_533

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 533 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 534 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_534

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 534 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 535 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_535

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 535 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 536 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_536

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 536 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 537 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_537

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 537 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 538 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_538

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 538 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 539 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_539

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 539 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 540 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_540

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 540 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 541 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_541

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 541 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 543 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_543

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 543 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 544 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_544

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 544 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 545 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_545

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 545 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 546 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_546

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 546 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written over a horizontal line.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 547 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_547

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 547 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 548 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_548

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 548 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 549 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_549  
DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 549 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 550 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_550

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 550 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 551 (as per Drawing No 36182 / 5B R04)  
Trillium Estate (Stage 5B), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14092\_551

DATE: 18/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 551 of the Trillium Estate (Stage 5B), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 14<sup>th</sup> August 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry', is written in a cursive style.

Justin Fry