



---

## FILL CERTIFICATE

PROJECT: Lot No 701 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_701

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 701, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 702 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_702

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 702, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 703 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_703

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 703, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 704 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_704

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 704, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 705 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_705

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 705, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 706 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_706

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 706, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 707 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_707

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 707, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 708 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_708

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 708, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry





---

## FILL CERTIFICATE

PROJECT: Lot No 709 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_709

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 709, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 710 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_710

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 710, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 711 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_711

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 711, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 712 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_712

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 712, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 713 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_713

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 713, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 714 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_714

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 714, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 715 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_715

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 715, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 716 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_716

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 716, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry





---

## FILL CERTIFICATE

PROJECT: Lot No 717 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_717

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 717, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 718 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_718

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 718, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 719 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_719

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 719, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 720 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_720

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 720, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 721 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_721

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 721, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 722 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_722

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 722, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 723 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_723

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 723, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



---

## FILL CERTIFICATE

PROJECT: Lot No 724 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_724

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 724, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry





---

## FILL CERTIFICATE

PROJECT: Lot No 725 (as per Drawing No 36182 / 7A R03)  
Trillium Estate (Stage 7A), Mickleham

CLIENT: Winslow Constructors Pty Ltd  
50 Barry Road  
CAMPBELLFIELD VIC 3061

REPORT NO: 14303\_725

DATE: 25/08/14

---

### SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 7A), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 725, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

### LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 6<sup>th</sup> March 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry