



FILL CERTIFICATE

PROJECT: Lot No 601 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_601

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 601, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 602 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_602

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 602, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 603 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_603

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 603, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 604 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_604

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 604, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 608 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_608

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 608, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 609 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_609

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 609, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 610 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_610

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 610, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 611 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_611

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 611, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 612 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_612

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 612, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 613 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_613

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 613, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 614 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_614

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 614, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 615 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_615

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 615, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 616 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_616

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 616, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 617 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_617

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 617, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 618 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_618

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 618, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 619 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_619

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 619, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 620 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_620

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 620, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 621 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_621

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 621, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 624 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_624

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 624, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 625 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_625

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 625, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 626 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_626

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 626, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 627 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_627

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 627, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 628 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_628

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 628, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 629 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_629

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 629, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 630 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_630

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 630, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 643 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_643

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 643, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 644 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_644

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 644, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 645 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_645

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 645, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink, appearing to read 'Justin Fry'.

Justin Fry



FILL CERTIFICATE

PROJECT: Lot No 646 (as per Drawing No 36182 / 6 R04)
Trillium Estate (Stage 6), Mickleham

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 14360_646

DATE: 02/10/14

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Trillium Estate (Stage 6), Mickleham, in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the allotments. On the completion of the earthworks and after examining the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd during the construction of the estate satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

With respect to Lot 646, the depth of fill materials that were placed during the current construction phase (excluding top soiling activities) was less than 0.3 metres. As a consequence of the limited depth of fill materials, field density testing was not considered warranted. However, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Winslow Constructors Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 9th July 2014.

A handwritten signature in black ink that reads 'Justin Fry'.

Justin Fry