



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/149
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2701

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out from the 13th of April 2021 to the 19th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/150
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2702

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out from the 13th of April 2021 to the 19th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/151
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2703

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 13th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER
Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/152
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2704

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 13th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER
Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/153
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2705

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 13th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/154
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2706

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 14th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/155
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2707

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 14th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/156
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2708

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 14th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER
Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/157
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2709

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 15th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/158
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2710

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 15th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/159
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2711

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 15th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/160
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2712

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 19th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/161
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2713

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 19th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/162
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2714

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 19th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER
Issue Date: 18/06/2021



**GEOTECHNICAL
LABORATORIES**

GEOTECHNICAL LABORATORIES PTY LTD

ABN 51 102 571 077

14 Ravenhall Way, Ravenhall Vic. 3023

Email: info@geolab.com.au

Telephone: (03) 8361-9140

CONTROLLED FILL CERTIFICATE

Report: 1862/163
Client: Drapers Civil Contracting Pty Ltd
Project: Armstrong Estate - Stage 27
Location: Allotment # 2715

INSPECTION & TESTING

At the request of Drapers Civil Contracting Pty Ltd, Geotechnical Laboratories has carried out inspection and testing of the stripping, material quality and compaction control procedures to ensure compliance with the requirements of AS 3798 (2007) Appendix B, Level 1 at the above noted project.

Compliance is based on material suitability inspections, compaction control testing and proof roll inspections performed by Geotechnical Laboratories Pty Ltd. Inspections and testing were carried out on the 19th of April 2021.

This report certifies that Drapers Civil Contracting Pty Ltd have adopted the required filling procedures to ensure the constructed fill for allotment 301 was performed to satisfy the level one criteria set out AS 3798 – 2007.

REMARKS

Allotment filling performed by Drapers Civil Contracting Pty Ltd for this site shall be classed as **CONTROLLED FILL** as per AS 2870 – 2011 Section 6.4.2 (a).

SPECIFICATIONS

Compaction Rate Required: Minimum 95% Standard as per AS 3798 – 2007 Section 5.2 Table 5.1 – Item 1.

Moisture Ratio Requirement: Not Specified

Fill Material Compliance: As per AS 3798 – 2007 Section 4.4 Suitable Materials.

Limitations: Any previous or subsequent earthworks will require a separate evaluation.

Sam Loza
LABORATORY MANAGER

Issue Date: 18/06/2021