

CIVIL GEOTECHNICAL SERVICES
ABN 26 474 013 724
6-8 ROSE AVENUE, CROYDON 3136
(PO BOX 678 CROYDON 3136)
TELEPHONE + 61 3 9723 0744
EMAIL nick.brock.civilgeotech@gmail.com

# **FILL CERTIFICATE**

PROJECT: Lot No 1101 (as per Drawing No 8974 E/11)

Delaray Estate (Stage 11), Clyde North

CLIENT: Winslow Constructors Pty Ltd

50 Barry Road

CAMPBELLFIELD VIC 3061

REPORT NO: 17381\_1101

DATE: 10 November 2017

# **SUMMARY**

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 1101 of the Delaray Estate (Stage 11), Clyde North in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

# LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 10 July 2017.

Nick Brock

FILL CERTIFICATE Page 1 of 1



CIVIL GEOTECHNICAL SERVICES
ABN 26 474 013 724
6-8 ROSE AVENUE, CROYDON 3136
(PO BOX 678 CROYDON 3136)
TELEPHONE + 61 3 9723 0744
EMAIL nick.brock.civilgeotech@gmail.com

# FILL CERTIFICATE

PROJECT: Lot No 1102 (as per Drawing No 8974 E/11)

Delaray Estate (Stage 11), Clyde North

CLIENT: Winslow Constructors Pty Ltd

50 Barry Road

CAMPBELLFIELD VIC 3061

REPORT NO: 17381\_1102

DATE: 10 November 2017

# **SUMMARY**

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 1102 of the Delaray Estate (Stage 11), Clyde North in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

# LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 10 July 2017.

Nick Brock

FILL CERTIFICATE Page 1 of 1